



Environmental and Laboratory Services
 90 ½ West Blackwell St., Dover, New Jersey 07801
 (973) 989-0010 P, (973) 989-0156 F

Analytical Results

Date: May 26, 2017
 Address: Montville Township School District
 86 River Road
 Montville, NJ 07045

Project: Hilldale School

Sample description: Drinking Water / 1st Draw / DWS5391-1
 Sample location: FIELD BLANK
 Sampled by: D. Mitchell
 Sample date: 05/06/17
 Time: 08:53
 Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/20/17	15:34	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5391-2
 Sample location: HS-FC-BY MAIN OFFICE
 Sampled by: D. Mitchell
 Sample date: 05/06/17
 Time: 08:54
 Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/20/17	15:41	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5391-3
 Sample location: HD-SO-MAIN-OFFICE TL
 Sampled by: D. Mitchell
 Sample date: 05/06/17
 Time: 08:55
 Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/20/17	15:47	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5391-4
 Sample location: HD-MO-NURSE
 Sampled by: D. Mitchell
 Sample date: 05/06/17
 Time: 08:56
 Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	8.47 µg/L	15 µg/L	05/20/17	15:53	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5391-5
 Sample location: HD-FC-BY MEDIA CTR RM 02-02
 Sampled by: D. Mitchell
 Sample date: 05/06/17
 Time: 08:57
 Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/20/17	16:00	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5391-6
 Sample location: HD-FC-BY MEDIA CTR RM 13-02
 Sampled by: D. Mitchell
 Sample date: 05/06/17
 Time: 08:57
 Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/20/17	16:07	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5391-7
 Sample location: HD-TL-TEACHERS LOUNGE
 Sampled by: D. Mitchell
 Sample date: 05/06/17
 Time: 08:59
 Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	3.63 µg/L	15 µg/L	05/20/17	16:13	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5391-8
 Sample location: HD-FC-BY ELECTRIC CLOSET
 Sampled by: D. Mitchell
 Sample date: 05/06/17
 Time: 09:05
 Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/20/17	16:20	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5391-9
 Sample location: HD-FC-MEDIA CTR RM 13-01
 Sampled by: D. Mitchell
 Sample date: 05/06/17
 Time: 09:02
 Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/20/17	16:33	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5391-10
 Sample location: HD-FC-MEDIA CTR RM 13-02
 Sampled by: D. Mitchell
 Sample date: 05/06/17
 Time: 09:03
 Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/20/17	16:39	1	2.00 µg/L

$\mu\text{g/L}$ = micrograms per liter

All testing was done within the required holding time.

I certify that these samples were analyzed in accordance with procedures approved by the New Jersey Department of Environmental Protection.

Susan VanVeen
Susan VanVeen, Lab Manager
NJ Laboratory Certification ID # 14013

5/22/17
Date

CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

#	Asc./HCl Vials	pH:	_____
#	HCl Vials	pH:	_____
#	Na ₂ S ₂ O ₃	Cl ₂ :	_____
#	HNO ₃ (150ml)	pH:	ca ✓
#	H ₂ SO ₄	pH:	_____
#	NaOH	pH:	_____
#	unpreserved		_____
#	other		_____
#	other		_____

Customer Name: Hilldale	report to:	Agra Environmental Services
Address: 123 Konner Ave		90½ West Blackwell Street
Montville	Nicole Mangili	Dover, NJ 07801
County/Municipality:	Nicole.Mangili@Montville.net	Phone: (973) 989-0010
Phone: Richard Medwin		Fax: (973) 989-0156
Work:		

Matrix Abbreviations: D - Drinking Water G- Groundwater W- Wastewater S- Soil SL- Sludge P-Pool L-Lake

Project:	Collection	PWSID# NJ					for laboratory use only	Field Analysis
Field ID	Date	Time	Grab	Comp	Matrix	# of Bottles	Preservative	ANALYSIS REQUESTED
Lab ID: DW55391								
Field Blank	5/6/17	0853	x			1	NH03	1ST DRAW PB 2.00 ug/L 5/20/17 1534 MF
HS-FC-BY MAIN OFFICE	5/6/17	0854	x			1	NH03	1ST DRAW PB 2.00 1541
HD-SO-MAIN OFFICE TL	5/6/17	0855	x			1	NH03	1ST DRAW PB 2.00 1547
HD-MO-NURSE	5/6/17	0850	x			1	NH03	1ST DRAW PB 8.47 1553
HD-FC-BY MEDIA CTR RM 02-02 L	5/6/17	0857	x			1	NH03	1ST DRAW PB 2.00 1600
HD-FC-BY MEDIA CTR RM 13-02 -R	5/6/17	0857	x			1	NH03	1ST DRAW PB 2.00 1607
HD-TL-TEACHER LOUNGE	5/6/17	0859	x			1	NH03	1ST DRAW PB 3.63 1613
HD-FC-BY ELECTRIC CLOSET 02	5/6/17	0905	x			1	NH03	1ST DRAW PB 2.00 1620
HD-FC-Media Ctr R13-01	5/6/17	0900	x			1	NH03	1ST DRAW PB 2.00 1633
HD-FC-Media Ctr R13-02	5/6/17	0903	x			1	NH03	1ST DRAW PB 2.00 1634

Sampled By (name/company): <i>D. Mitchell</i>	State Forms Needed (circle one): Yes or No			indicate laboratory location where analysis requested was performed		
	NJDEP Laboratory Certification (Dover, NJ) #14013					
	NJDEP Laboratory Certification (Marlboro, NJ) #13033					
Reporting Requirements (Check Box):	Standard	NJ Reduced	Other (Specify)	Cooler Temperature Upon Receipt at lab:		

Sample Custody Exchanges (Please use full legal signature)						Scanned _____	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:		
<i>D. Mitchell</i>	5/16/17	0953	<i>[Signature]</i>	5/18/17	0831		
Relinquished By:	Date:	Time:	Received By:	Date:	Time:		
Relinquished By:	Date:	Time:	Received By:	Date:	Time:		
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	Date Faxed _____	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	Invoice Number _____	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	Is sample known to be hazardous? (circle one) Yes or No	