



Environmental and Laboratory Services

90 1/2 West Blackwell St., Dover, New Jersey 07801

(973) 989-0010 P, (973) 989-0156 F

Analytical Results

Date: May 26, 2017

Address: Montville Township School District
86 River Road
Montville, NJ 07045

Project: **Montville High School**

Sample description: Drinking Water / 1st Draw / DWS5396-1
Sample location: FIELD BLANK
Sampled by: D. Mitchell
Sample date: 05/06/17
Time: 05:58
Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/20/17	18:15	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5396-2
Sample location: MHS-FC-BOYS-LR
Sampled by: D. Mitchell
Sample date: 05/06/17
Time: 06:05
Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/20/17	18:21	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5396-3
Sample location: MHS-FC-BY-ROTUNDA RAMP
Sampled by: D. Mitchell
Sample date: 05/06/17
Time: 06:08
Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/20/17	18:26	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5396-4
Sample location: MHS-FC-BY AUX GYM-01
Sampled by: D. Mitchell
Sample date: 05/06/17
Time: 06:22
Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/20/17	18:32	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5396-5
 Sample location: MHS-FC-BY AUX GYM-02
 Sampled by: D. Mitchell
 Sample date: 05/06/17
 Time: 06:23
 Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/20/17	18:38	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5396-6
 Sample location: MHS-FC-WRESTLING GYM-01
 Sampled by: D. Mitchell
 Sample date: 05/06/17
 Time: 06:25
 Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	11.8 µg/L	15 µg/L	05/20/17	18:49	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5396-7
 Sample location: MHS-FC-WRESTLING GYM-02
 Sampled by: D. Mitchell
 Sample date: 05/06/17
 Time: 06:26
 Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	49.3 µg/L	15 µg/L	05/20/17	19:00	4	8.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5396-8
 Sample location: MHS-FC-WEIGHT ROOM-01
 Sampled by: D. Mitchell
 Sample date: 05/06/17
 Time: 06:29
 Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	2.06 µg/L	15 µg/L	05/20/17	19:05	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5396-9
 Sample location: MHS-FC-WEIGHT RM-02
 Sampled by: D. Mitchell
 Sample date: 05/06/17
 Time: 06:30
 Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	2.55 µg/L	15 µg/L	05/20/17	19:11	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5396-10
 Sample location: MHS-FC-BY ROTUNDA STAIRS
 Sampled by: D. Mitchell
 Sample date: 05/06/17
 Time: 06:06
 Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/20/17	19:16	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5396-11
 Sample location: MHS-IM-KITCHEN DELI
 Sampled by: D. Mitchell
 Sample date: 05/06/17
 Time: 06:00
 Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/20/17	19:22	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5396-12
 Sample location: MHS-KO-KITCHEN-DELI-01
 Sampled by: D. Mitchell
 Sample date: 05/06/17
 Time: 06:34
 Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	5.71 µg/L	15 µg/L	05/20/17	19:28	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5396-13
 Sample location: MHS-KO-KITCHEN-DELI-02
 Sampled by: D. Mitchell
 Sample date: 05/06/17
 Time: 06:35
 Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/20/17	19:33	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5396-14
 Sample location: MHS-KO-KITCHEN-01
 Sampled by: D. Mitchell
 Sample date: 05/06/17
 Time: 06:36
 Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	2.69 µg/L	15 µg/L	05/20/17	19:50	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5396-15
 Sample location: MHS-KO-KITCHEN-02
 Sampled by: D. Mitchell
 Sample date: 05/06/17
 Time: 06:37
 Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	4.22 µg/L	15 µg/L	05/20/17	19:56	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5396-16
 Sample location: MHS-KO-KITCHEN-03
 Sampled by: D. Mitchell
 Sample date: 05/06/17
 Time: 06:37
 Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	6.12 µg/L	15 µg/L	05/20/17	20:01	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5396-17
 Sample location: MHS-KO-KITCHEN-04
 Sampled by: D. Mitchell
 Sample date: 05/06/17
 Time: 06:39
 Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	6.79 µg/L	15 µg/L	05/20/17	20:12	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5396-18
 Sample location: MHS-TL-TEACHERS LOUNGE
 Sampled by: D. Mitchell
 Sample date: 05/06/17
 Time: 06:38
 Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/20/17	20:35	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5396-19
 Sample location: MHS-HE-505-01
 Sampled by: D. Mitchell
 Sample date: 05/06/17
 Time: 06:44
 Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/20/17	20:41	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5396-20
 Sample location: MHS-HE-505-02
 Sampled by: D. Mitchell
 Sample date: 05/06/17
 Time: 06:44
 Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/20/17	20:46	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5396-21
 Sample location: MHS-HE-505-03
 Sampled by: D. Mitchell
 Sample date: 05/06/17
 Time: 06:45
 Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/20/17	20:52	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5396-22
 Sample location: MHS-HE-505-04
 Sampled by: D. Mitchell
 Sample date: 05/06/17
 Time: 06:45
 Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/20/17	20:57	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5396-23
 Sample location: MHS-HE-505-05
 Sampled by: D. Mitchell
 Sample date: 05/06/17
 Time: 06:46
 Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/20/17	21:08	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5396-24
 Sample location: MHS-FC-BY 506-01
 Sampled by: D. Mitchell
 Sample date: 05/06/17
 Time: 06:47
 Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/20/17	21:14	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5396-25
 Sample location: MHS-FC-BY-506-02
 Sampled by: D. Mitchell
 Sample date: 05/06/17
 Time: 06:48
 Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/20/17	21:20	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5396-26
 Sample location: MHS-FC-BY 506-03
 Sampled by: D. Mitchell
 Sample date: 05/06/17
 Time: 06:48
 Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/20/17	21:25	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5396-27
 Sample location: MHS-FC-BY 506-04
 Sampled by: D. Mitchell
 Sample date: 05/06/17
 Time: 06:48
 Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/20/17	21:31	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5396-28
 Sample location: MHS-FC-BY-617B-01
 Sampled by: D. Mitchell
 Sample date: 05/06/17
 Time: 06:50
 Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/20/17	21:37	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5396-29
 Sample location: MHS-FC-BY 617-B-02
 Sampled by: D. Mitchell
 Sample date: 05/06/17
 Time: 06:50
 Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/20/17	21:42	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5396-30
 Sample location: MHS-FC-GIRLS LOCKER ROOM
 Sampled by: D. Mitchell
 Sample date: 05/06/17
 Time: 06:20
 Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	3.05 µg/L	15 µg/L	05/20/17	21:48	1	2.00 µg/L

µg/L = micrograms per liter

All testing was done within the required holding time.

I certify that these samples were analyzed in accordance with procedures approved by the New Jersey Department of Environmental Protection.

Susan VanVeen
 Susan VanVeen, Lab Manager
 NJ Laboratory Certification ID # 14013

5/28/17
 Date

CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

Customer Name: Montville High School
 Address: 100 Horseneck Rd
 County/Municipality: Montville NJ
 Phone: Richard Medwin
 Work: 201-259-3954

report to: Agra Environmental Services
90 1/2 West Blackwell Street
Dover, NJ 07801
 Phone: (973) 989-0010
 Fax: (973) 989-0156

Nicole Mangilli
 Nicole.Mangilli@Montville.net

Asc./HCl Vials pH: LA
 # HCl Vials pH: LA
 # Na₂S₂O₃ Cl₂: LA
 # HNO₃ (500 ml) pH: LA
 # H₂SO₄ pH: LA
 # NaOH unpreserved
 # other
 # other

Matrix Abbreviations: D - Drinking Water G - Groundwater W - Wastewater S - Soil SL - Sludge P - Pool L - Lake		Collection		PWSID# NJ				for laboratory use only		Field Analysis
Field ID	Lab ID:	Date	Time	Grab	Comp	Matrix	# of Bottles	Preservative	ANALYSIS REQUESTED	
Field Blank	DW55396	5/6/17	6:58	x			1	NHO3	1ST DRAW PB	1815 MF
MHS-FC-boys-LR		5/6/17	6:05	x			1	NHO3	1ST DRAW PB	1821
MHS-FC-BY ROTUNDA RAMP		5/6/17	6:07	x			1	NHO3	1ST DRAW PB	1826
MHS-FC-BY AUX GYM-01		5/6/17	6:08	x			1	NHO3	1ST DRAW PB	1832
MHS-FC-BY AUX GYM-02		5/6/17	6:22	x			1	NHO3	1ST DRAW PB	1838
MHS-FC-Wrestling Gym-01		5/6/17	6:25	x			1	NHO3	1ST DRAW PB	1849
MHS-FC-WRESTLING GYM-02		5/6/17	6:26	x			1	NHO3	1ST DRAW PB	1900
MHS-FC-Weight Rm-01		5/6/17	6:29	x			1	NHO3	1ST DRAW PB	1905
MHS-FC-WEIGHT RM-02		5/6/17	6:30	x			1	NHO3	1ST DRAW PB	1911
MHS-FC-BY ROTUNDA STAIRS		5/6/17	6:00	x			1	NHO3	1ST DRAW PB	1916

State Forms Needed (circle one): Yes or No
 NJDEP Laboratory Certification (Dover, NJ) #14013
 NJDEP Laboratory Certification (Marlboro, NJ) #13033

Reporting Requirements (Check Box):
 Standard NJ Reduced Other (Specify)

Relinquished By: [Signature] Date: 5/6/17 Time: 09:55
 Relinquished By: _____ Date: _____ Time: _____
 Relinquished By: _____ Date: _____ Time: _____
 Relinquished By: _____ Date: _____ Time: _____

Received By: [Signature] Date: 5/8/17 Time: 08:34
 Received By: _____ Date: _____ Time: _____
 Received By: _____ Date: _____ Time: _____
 Received By: _____ Date: _____ Time: _____

Scanned: _____
 Date Faxed: _____
 Invoice Number: _____
 Is sample known to be hazardous? (circle one)
 Yes or No

CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST



Agra Environmental Services
 90½ West Blackwell Street
 Dover, NJ 07801
 Phone: (973) 989-0010
 Fax: (973) 989-0156

Customer Name: Montville High School
 Address: 100 Horseneck Rd
 County/Municipality: Montville NJ
 Phone: Richard Medwin
 Work: Nicole Mangili
Nicole.Mangili@Montville.net

report to: _____
 Matrix Abbreviations: **D - Drinking Water** **G - Groundwater** **W - Wastewater** **S - Soil** **SL - Sludge** **P - Pool** **L - Lake**
 Project: _____ for laboratory use only
 Page 1 of 1
 Field Analysis

Field ID	Lab ID:	Collection		Grab	Comp	Matrix	# of Bottles	Preservative	ANALYSIS REQUESTED	P-Pool	L-Lake	Field Analysis
		Date	Time									
MHS-IM-KITCHEN DELI	DWS5396	5/6/17	0634	x			1	NH03	1ST DRAW PB			1928
MHS-KO-KITCHEN-DELI-01		5/6/17	0634	x			1	NH03	1ST DRAW PB			1933
MHS-KO-KITCHEN-DELI-02		5/6/17	0635	x			1	NH03	1ST DRAW PB			1950
MHS-KO-KITCHEN-01		5/6/17	0636	x			1	NH03	1ST DRAW PB			1956
MHS-KO-KITCHEN-02		5/6/17	0637	x			1	NH03	1ST DRAW PB			2001
MHS-KO-KITCHEN-03		5/6/17	0638	x			1	NH03	1ST DRAW PB			2012
MHS-TL-TEACHERS LOUNGE		5/6/17	0638	x			1	NH03	1ST DRAW PB			2035
MHS-HE-505-01		5/6/17	0644	x			1	NH03	1ST DRAW PB			2041
MHS-HE-505-02		5/6/17	0644	x			1	NH03	1ST DRAW PB			2046

State Forms Needed (circle one): Yes or No

NJDEP Laboratory Certification (Dover, NJ) #14013

NJDEP Laboratory Certification (Marlboro, NJ) #13033

Reporting Requirements (Check Box):

NJ Reduced Other (Specify)

Standard _____ Cooler Temperature Upon Receipt at lab: _____

Sample Custody Exchanges (Please use full legal signature)

Relinquished By: <u>[Signature]</u>	Date: <u>5/6/17</u>	Time: <u>0953</u>	Received By: <u>[Signature]</u>	Date: <u>5/18/17</u>	Time: <u>0835</u>
Relinquished By: _____	Date: _____	Time: _____	Received By: _____	Date: _____	Time: _____
Relinquished By: _____	Date: _____	Time: _____	Received By: _____	Date: _____	Time: _____
Relinquished By: _____	Date: _____	Time: _____	Received By: _____	Date: _____	Time: _____

Scanned _____

Date Faxed _____ Invoice Number _____

Is sample known to be hazardous? (circle one)
 Yes or No

CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

Customer Name:	report to:	Agra Environmental Services
Address:	Montville High School 100 Horseneck Rd	90½ West Blackwell Street Dover, NJ 07801
County/Municipality:	Montville NJ	Phone: (973) 989-0010
Phone:	Richard Medwin	Fax: (973) 989-0156
Work:		



Matrix Abbreviations: D - Drinking Water G - Groundwater W - Wastewater S - Soil SL - Sludge P - Pool L - Lake		PWSID# NJ		for laboratory use only		Page 1 of 1			
Field ID	Lab ID:	Collection	Grab	Comp	Matrix	# of Bottles	Preservative	ANALYSIS REQUESTED	Field Analysis
MHS-HE-505-03	-A	5/6/17 0645	x			1	NH03	1ST DRAW PB 2.00 ug/L 5/20/17 2052	MF
MHS-HE-505-04	-A	5/6/17 0645	x			1	NH03	1ST DRAW PB 2.00	2057
MHS-HE-505-05	-A	5/6/17 0646	x			1	NH03	1ST DRAW PB 2.00	2108
MHS-FC-BY 506-01	-A	5/6/17 0647	x			1	NH03	1ST DRAW PB 2.00	2114
MHS-FC-BY 506-02	-A	5/6/17 0648	x			1	NH03	1ST DRAW PB 2.00	2120
MHS-FC-BY 506-03	-A	5/6/17 0648	x			1	NH03	1ST DRAW PB 2.00	2125
MHS-FC-BY 506-04	-A	5/6/17 0648	x			1	NH03	1ST DRAW PB 2.00	2131
MHS-FC-BY 617B-01	-A	5/6/17 0650	x			1	NH03	1ST DRAW PB 2.00	2137
MHS-FC-BY 617-B-02	-A	5/6/17 0650	x			1	NH03	1ST DRAW PB 2.00	2142
		5/6/17	x			1	NH03	1ST DRAW PB 2.00	2148

State Forms Needed (circle one): Yes or No

NJDEP Laboratory Certification (Dover, NJ) #14013

NJDEP Laboratory Certification (Marlboro, NJ) #13033

Indicate laboratory location where analysis requested was performed

Reporting Requirements (Check Box): NJ Reduced Other (Specify)

Cooler Temperature Upon Receipt at lab: _____

Sample Custody Exchanges (Please use full legal signature)

Relinquished By:	Date:	Time:	Received By:	Date:	Time:	Scanned:
<i>D. Medwin</i>	5/6/17		<i>[Signature]</i>	5/18/17	0835	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	

Date Faxed _____ Invoice Number _____

Is sample known to be hazardous? (circle one)

CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

Customer Name:	report to:	Agra Environmental Services
Address:	90 1/2 West Blackwell Street Dover, NJ 07801	
County/Municipality:	Montville NJ	
Phone:	Phone: (973) 989-0010	
Work:	Fax: (973) 989-0156	
Matrix Abbreviations:	W- Wastewater	S- Soil
	G- Groundwater	P- Pool
	L- Lake	



Project:	Collection		PWSID# NJ	W- Wastewater	S- Soil	P- Pool	L- Lake	for laboratory use only	Field Analysis
	Date	Time							
Field ID #C-Girls LR	5/6/17	0620							ANALYSIS REQUESTED
Girls Locker Rm. 130	5/6/17								1ST DRAW PB 3.05 w/ll. 5/6/17 2-48 MF
	5/6/17								1ST DRAW PB
	5/6/17								1ST DRAW PB
	5/6/17								1ST DRAW PB
	5/6/17								1ST DRAW PB
	5/6/17								1ST DRAW PB
	5/6/17								1ST DRAW PB
	5/6/17								1ST DRAW PB
	5/6/17								1ST DRAW PB
	5/6/17								1ST DRAW PB

State Forms Needed (circle one): Yes or No

indicate laboratory location where analysis requested was performed

NJDEP Laboratory Certification (Dover, NJ) #14013

NJDEP Laboratory Certification (Marlboro, NJ) #13033

Reporting Requirements (Check Box):

Standard	NJ Reduced	Other (Specify)
		Cooler Temperature Upon Receipt at lab:

Sample Custody Exchanges (Please use full legal signature)

Relinquished By: *[Signature]* Date: 5/6/17 Time: 0933

Received By: *[Signature]* Date: 5/8/17 Time: 0835

Relinquished By: *[Signature]* Date: _____ Time: _____

Received By: _____ Date: _____ Time: _____

Relinquished By: _____ Date: _____ Time: _____

Received By: _____ Date: _____ Time: _____

Relinquished By: _____ Date: _____ Time: _____

Received By: _____ Date: _____ Time: _____

Scanned: _____

Date Faxed: _____

Invoice Number: _____

Is sample known to be hazardous? (circle one)